



STATE OF MARYLAND
 DEPARTMENT OF LABOR, LICENSING, AND REGULATION
 DIVISION OF LABOR AND INDUSTRY
 SAFETY INSPECTION UNIT
 1100 N. EUTAW STREET BALTIMORE, MD 21201
 410-767-2990

**ANNUAL AND FIVE YEAR
 TEST REPORTING FORM**
FIRE SERVICE / EMERGENCY POWER

The Division is authorizing qualified personnel to perform specific tests during the annual and five year inspection periods.

ALL WORK IS TO BE PERFORMED IN ACCORDANCE WITH THE REQUIREMENTS OF THE APPROPRIATE ASME A17.1 CODE FOR ELEVATORS, DUMBWAITERS, ESCALATORS, AND MOVING WALKS AND ASME/ANSI A17.2 INSPECTORS MANUAL FOR ELEVATORS AND ESCALATORS. INDICATE BELOW SPECIFIC CODE USED FOR EACH TEST OR INSPECTION.

For each elevator tested, list the State Registration number found in the elevator machine room: _____

A. SMOKE SENSING DEVICES – Applicable Code Year: _____

All smoke sensors related to the elevator operation except designated level, returned elevator(s) to the designated level (key floor) YES NO. The designated floor sensor sent the elevator(s) to the alternate level, floor number _____ as required by the ASME A17.1 Elevator Code.

During the Annual Safety Inspection, the State of Maryland will test all other fire service related equipment prescribed by the above Code, including the Phase I key-switch and all Phase II operation.

B. STAND-BY EMERGENCY POWER TEST - Applicable Code Year: _____

CHECK ONE: ANNUAL TEST ASME A17.1 FIVE YEAR TEST ASME A17.1
 OTHER: _____

Annually, elevator(s) equipped with stand-by emergency power are required to be tested using the emergency power system with no load. The elevator(s) shall be tested with 125% rated load during the 5 year-test.

1. Did the elevator(s) operate simultaneously while on stand-by emergency power? YES NO

If NO, explain: _____

2. Did the elevators operate in accordance with the above elevator Code? YES NO

C. DEVICE FOR DISCONNECTING MAIN LINE POWER - Applicable Code Year: _____

The ASME A17.1 Elevator Code requires a means to automatically disconnect the main line power to the affected elevator upon or prior to the application of water.

1. Sprinklers are installed in the elevator:

- ◆ Machine room YES NO
- ◆ Elevator hoistway YES NO

2. Were disconnecting devices tested? YES NO

Did they function as required? YES NO

Site Name: _____
Address: _____
City, State, Zip: _____
Testing Firm: _____
Date Tested: _____
Printed Name of Authorized Agent: _____
Authorized Agent's Signature: _____

WHEN COMPLETED, LEAVE FORM IN THE ELEVATOR MACHINE ROOM.